



ELECTRICAL CERTIFICATE OF COMPLIANCE & ELECTRICAL SAFETY CERTIFICATE



REFERENCE/CERTIFICATE ID NO.: 02262- Waterblaster Outlet

This form has been designed to be used by licensed electrical workers to certify that installations or Part installations under Part 1 or Part 2 of AS/NZS 3000 are safe to be connected to the specified system of electrical supply.

Location Details:

46 Water Street, Whangarei

Contact-Details: (Name and Address)

Lamberts
46 Water Street

Name of Electrical worker:

Brian Firth

Registration/Practising licence number:

I 090285

Phone & Email:

027 355 2248 Brian.Firth@mckay.co.nz

Name & registration number of person(s) supervised:

Dontay Fusitua-Joass

Certificate of Compliance

Type of Work:

Additional Alteration New Work Repair

The prescribed electrical work is:

Low Risk General High-risk (Specify)

Means of Compliance:

Part 1 of AS/NZS 3000 Part 2 of AS/NZS 3000

Additional Standards or electrical code of practice were required: Y/N (if Yes, Specify)

Date or Date Range that prescribed electrical was undertaken: 19/03/2026

Contains fittings that are safe to connect to a power supply? Y/N

Specify type of supply system: MEN 230v

The installation has an earthing system that is correctly rated (where applicable) Y/N

Parts of the installation to which this certificate relates that are safe to connect to a power supply?

All Parts (Specify) 15 amp socket-outlet for water blaster

The work has been done in accordance with a certified design: Y/N

If yes identify the certified design including name, date and version. Also attach a copy of the certified design to this certificate. (Or provide reference to readily accessible electronic format, eg Internet link.)

Identify:
Link:

The work relies on manufacturer's instructions: Y/N

If yes identify the instruction manual including name, date and version. Also attach a copy of manufacturers instructions to this certificate. (Or provide reference to readily accessible electronic format, eg Internet link.)

Identify: <https://www.jarussell.co.nz/Compliance>
Link:

The work relies on a Supplier Declaration of Conformity (SDoC): Y/N

If yes - identify the SDoC including name, date and version OR EESS registration. Also attach a copy of the SDoC to this certificate. (Or provide reference to readily accessible electronic format, eg Internet link.)

Identify: <https://www.jarussell.co.nz/Compliance>
Link:

The installation has been satisfactorily tested in accordance with the Electricity (Safety) Regulations 2010 Y/N

Description of Work:
Replaced faulty 15 amp GPO with a commercial grade 15 amp GPO.

DB1-B4.

RCD test results: x1@0Deg = 28mS. x1@180Deg = 18mS. Ramp = 22mA.

Test Results (Provide Values)	
Polarity (Independent earth):	Correct
Insulation resistance:	680 M-ohm M-Ohms
Earth continuity:	0.35 ohm Ohms
Bonding:	n/a Ohms
Fault Loop impedance:	0.56 ohm Ohms
PSCC	kA
Other (Specify)	PSCC = 0.4 kA

By signing this document, I certify that the completed prescribed electrical work to which this Certificate of Compliance applies has been done lawfully and safely, and the information in the certificate is correct.

Certifiers signature: Brian Firth Date: 19/03/2026

Electrical Safety Certificate

By signing this document I certify that the installation, or part of the installation, to which this Electrical Safety Certificate applies is connected to a power supply and is safe to use.

Certifiers name: Brian Firth

Registration/Practising licence number: I 090285

Certifiers signature: Brian Firth

Certificate Issue Date: 19/03/2026

Connection Date: 19/03/2026

CUSTOMER COPY - THIS IS AN IMPORTANT DOCUMENT AND SHOULD BE RETAINED FOR A MINIMUM OF 7 YEARS